

# EU-Type Examination - Production Type Certificate

This is to certify that:

Jactone Products Limited  
Springvale Business Park  
Springvale Avenue  
Bilston  
WV14 0QL  
United Kingdom

Holds Certificate Number:

CE 603059

In respect of:

## Fire Extinguisher Assemblies

On the basis of our examination under the requirements of Council Directive 2014/68/EU Module B of the Pressure Equipment Directive, as transposed into the law of The Netherlands Warenwetbesluit drukapparatuur 2016.

For and on behalf of BSI, a Notified  
Body for the above Directive  
(Notified Body Number 2797):



Denelise L'Ecluse, Managing Director Assurance - Continental  
Europe

First Issued: 2014-06-20

Latest Issue: 2023-07-07

Expiry Date: 2032-05-21



Page: 1 of 4

# EU-Type Examination - Production Type Certificate

No. CE 603059

## Additional Information

### Limitations of Certificate Validity

Products: Portable LP fire extinguisher assemblies in the following models: -

- EPS12 – 12 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EPS9 – 9 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EWS9 – 9 Litre Water – PS = 17.8 bar g and TS = 0°C to +60°C
- EPVS9 – 9 Litre Water/Polymer – PS = 17.8 bar g and TS = 0°C to +60°C
- EFS9ECO – 9 Litre Eco-Foam – PS = 17.8 bar g and TS = 0°C to +60°C
- EPS6 – 6 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EWS6 – 6 Litre Water – PS = 17.8 bar g and TS = 0°C to +60°C
- EWMS6 – 6 Litre Water Mist – PS = 17.8 bar g and TS = 0°C to +60°C
- EFS6Plus – 6 Litre Foam Plus – PS = 17.8 bar g and TS = 0°C to +60°C
- EFS6ECO – 6 Litre Eco-Foam – PS = 17.8 bar g and TS = 0°C to +60°C
- EWCS6 – 6 Litre Wet Chemical – PS = 9.6 bar g and TS = 0°C to +60°C
- EPVS45 – 4.5 Litre Water/Polymer – PS = 17.8 bar g and TS = 0°C to +60°C
- EPS4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EWMS3 – 3 Litre Water Mist – PS = 17.8 bar g and TS = 0°C to +60°C
- EWCS3 – 3 Litre Wet Chemical – PS = 9.6 bar g and TS = 0°C to +60°C
- EPS2 – 2 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EGS9 – 9 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C
- EGS6 – 6 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C
- EGS2 – 2 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C
- EFAS4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EFAS2 – 2 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C
- EFAS1 – 1 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

First Issued: 2014-06-20

Latest Issue: 2023-07-07

Expiry Date: 2032-05-21

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.  
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.

# EU-Type Examination - Production Type Certificate

No. CE 603059

Products: Portable HP fire extinguisher assemblies in the following models: -

EC2, EC2F & EC2FPA – 2 kg Carbon Dioxide – PS = 169.3 bar g and TS = -20°C to +60°C

EC5 & EC5PA – 5 kg Carbon Dioxide – PS = 169.3 bar g and TS = -20°C to +60°C

Products: Fire extinguisher assemblies for use in suppression systems in the following models: -

FSGAKGI12 – 12 Litre Wet Chemical – PS = 23.7 bar g and TS = 0°C to +60°C

FSGAPI9 – 9 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAFI9 – 9 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C

FSGANI9 – 9 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAKGI8 – 8 Litre Wet Chemical – PS = 23.7 bar g and TS = 0°C to +60°C

FSGAPI72E – 7.2 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C

FSGANI6 – 6 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPI6 – 6 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPI6E – 6 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C

FSGAMOI6 – 6 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAFI5 – 5 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAPI42E – 4.2 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C

FSGAND4 – 4 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGANI4 – 4 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPD4 – 4 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPI4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAMOI4 – 4 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAND3 – 3 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGANI3 – 3 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPD3 – 3 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPI3 – 3 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAMOI3 – 3 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAND25 – 2.5 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAPD2 – 2 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

First Issued: 2014-06-20

Latest Issue: 2023-07-07

Expiry Date: 2032-05-21

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.

To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.

# EU-Type Examination - Production Type Certificate

No. CE 603059

FSGAND2 – 2 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGANI2 – 2 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAKGI2 – 2 Litre Wet Chemical – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAMOI2 – 2 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAND1 – 1 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAFD1 – 1 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI4 – 4 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI6 – 6 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI9 – 9 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

All as described in technical file no. JT-PED-001 Rev. 12

First Issued: 2014-06-20

Latest Issue: 2023-07-07

Expiry Date: 2032-05-21

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.

To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.