

# UKCA Type Examination – Production Type

This is to certify that:

Jactone Products Limited  
Springvale Business Park  
Springvale Avenue  
Bilston  
WV14 0QL  
United Kingdom

Holds Certificate Number:

UKCA 745988

In respect of:

## Fire Extinguisher Assemblies

On the basis of our examination under the requirements of the Pressure Equipment (Safety) Regulations (SI 2016/1105) as amended by the Product Safety and Metrology etc (Amendment etc)(EU Exit) Regulations 2020 (SI 2020/676) for Conformity Assessment Procedure Module B - Type Examination - Production Type.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2021-04-26

Latest Issue: 2023-07-07

Effective Date: 2023-07-07

Expiry Date: 2032-05-21

Page: 1 of 4



# UKCA Type Examination – Production Type

No. UKCA 745988

## Additional Information

### Limitations of Certificate Validity

Products: Portable LP fire extinguisher assemblies in the following models: -

EPS12 – 12 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EPS9 – 9 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EWS9 – 9 Litre Water – PS = 17.8 bar g and TS = 0°C to +60°C

EPVS9 – 9 Litre Water/Polymer – PS = 17.8 bar g and TS = 0°C to +60°C

EFS9ECO – 9 Litre Eco-Foam – PS = 17.8 bar g and TS = 0°C to +60°C

EPS6 – 6 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EWS6 – 6 Litre Water – PS = 17.8 bar g and TS = 0°C to +60°C

EWMS6 – 6 Litre Water Mist – PS = 17.8 bar g and TS = 0°C to +60°C

EFS6Plus – 6 Litre Foam Plus – PS = 17.8 bar g and TS = 0°C to +60°C

EFS6ECO – 6 Litre Eco-Foam – PS = 17.8 bar g and TS = 0°C to +60°C

EWCS6 – 6 Litre Wet Chemical – PS = 9.6 bar g and TS = 0°C to +60°C

EPVS45 – 4.5 Litre Water/Polymer – PS = 17.8 bar g and TS = 0°C to +60°C

EPS4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EWMS3 – 3 Litre Water Mist – PS = 17.8 bar g and TS = 0°C to +60°C

EWCS3 – 3 Litre Wet Chemical – PS = 9.6 bar g and TS = 0°C to +60°C

EPS2 – 2 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EGS9 – 9 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

EGS6 – 6 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

EGS2 – 2 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

EFAS4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EFAS2 – 2 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

EFAS1 – 1 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C

First Issued: 2021-04-26

Latest Issue: 2023-07-07

Effective Date: 2023-07-07

Expiry Date: 2032-05-21

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

# UKCA Type Examination – Production Type

No. UKCA 745988

Products: Portable HP fire extinguisher assemblies in the following models: -  
EC2, EC2F & EC2FPA – 2 kg Carbon Dioxide – PS = 169.3 bar g and TS = -20°C to +60°C  
EC5 & EC5PA – 5 kg Carbon Dioxide – PS = 169.3 bar g and TS = -20°C to +60°C

Products: Fire extinguisher assemblies for use in suppression systems in the following models: -

FSGAKGI12 – 12 Litre Wet Chemical – PS = 23.7 bar g and TS = 0°C to +60°C  
FSGAPI9 – 9 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAFI9 – 9 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C  
FSGANI9 – 9 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAKGI8 – 8 Litre Wet Chemical – PS = 23.7 bar g and TS = 0°C to +60°C  
FSGAPI72E – 7.2 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C  
FSGANI6 – 6 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPI6 – 6 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPI6E – 6 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C  
FSGAMOI6 – 6 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAFI5 – 5 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C  
FSGAPI42E – 4.2 kg Dry Powder – PS = 21.4 bar g and TS = -40°C to +60°C  
FSGAND4 – 4 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGANI4 – 4 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPD4 – 4 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPI4 – 4 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAMOI4 – 4 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAND3 – 3 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGANI3 – 3 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPD3 – 3 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPI3 – 3 kg Dry Powder – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAMOI3 – 3 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAND25 – 2.5 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C  
FSGAPD2 – 2 kg Dry Powder (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

First Issued: 2021-04-26

Latest Issue: 2023-07-07

Effective Date: 2023-07-07

Expiry Date: 2032-05-21

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# UKCA Type Examination – Production Type

No. UKCA 745988

FSGAND2 – 2 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGANI2 – 2 kg FK-5-1-12 – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAKGI2 – 2 Litre Wet Chemical – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAMOI2 – 2 kg Monnex – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAND1 – 1 kg FK-5-1-12 (Direct) – PS = 17.8 bar g and TS = -20°C to +60°C

FSGAFD1 – 1 Litre Foam – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI4 – 4 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI6 – 6 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

FSGAGI9 – 9 Litre Gel – PS = 17.8 bar g and TS = 0°C to +60°C

All as described in technical file no. JT-UKCA-001 Rev. 3

First Issued: 2021-04-26

Latest Issue: 2023-07-07

Effective Date: 2023-07-07

Expiry Date: 2032-05-21

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.